

Certificate



Certificate no.

CU 72131588 01

License Holder:

Northeast Power Systems, Inc.
66 Carey Road
Queensbury NY 12804
USA

Manufacturing Plant:

Northeast Power Systems, Inc.
66 Carey Road
Queensbury NY 12804
USA

Test report no.: USA- 30572715 006

Client Reference: Paul Steciuk

Tested to:

IEEE C37.20.3-2001
C22.2 No. 190-M1985 + GI1 + GI2 (R2004)

Certified Product: Medium-Voltage Metal-Enclosed Capacitor

License Fee - Units

Bank and Harmonic Filter

Model Designation: MV-ACB, MV-AHFB

Rated Voltage: 2.4-38kV max.

Rated Power: 60000 kVar (capacitor bank)

60000 kVar (harmonic filter bank)

Rated Current: see Appendix (Constr. Data Form)

Protection Class: I

Special Remarks: To be installed according to the licensee's installation instructions. Site safety testing is required at installation, before equipment is placed into operation. No safety testing was performed during product evaluation. Replaces Certificate US72071127.

7

7

Appendix: 1, 1-4

Licensed Test mark:



Date of Issue

(day/mo/yr)

19/07/2013